



Analysis Report

Total Lead by ICP-MS

Chain of Custody: Pb-0161
Facility: Fairfax R-III

Sample Matrix: Water
Method of Analysis: EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0161-001	FFX-TEACH-WR-HS-PS-001	12/19/2023	Draw	ND	1.0
Pb-0161-002	FFX-TEACH-WR-HS-MTP-PS-002	12/19/2023	Draw	ND	1.0
Pb-0161-003	FFX-TEACH-WR-IM-PS-003	12/19/2023	Draw	ND	1.0
Pb-0161-004	FFX-OG-DF-PS-004	12/19/2023	Draw	ND	1.0
Pb-0161-005	FFX-OG-DW-PS-005	12/19/2023	Draw	ND	1.0
Pb-0161-006	FFX-OG-CONC-FP PS-006	12/19/2023	Draw	ND	1.0
Pb-0161-007	FFX-VAR-GLKR-HSR PS-007	12/19/2023	Draw	ND	1.0
Pb-0161-008	FFX-VAR-GLKR-HSL PS-008	12/19/2023	Draw	1.09	1.0
Pb-0161-009	FFX-VAR-GLKR-RTL-SHR-1 PS-009	12/19/2023	Draw	3.50	1.0
Pb-0161-010	FFX-VAR-GLKR-RTL-SHR-2 PS-010	12/19/2023	Draw	2.45	1.0
Pb-0161-011	FFX-VAR-GLKR-RTL-SHR-3 PS-011	12/19/2023	Draw	3.96	1.0
Pb-0161-012	FFX-VAR-GLKR-RTL-SHR-4 PS-012	12/19/2023	Draw	10.3	1.0
Pb-0161-013	FFX-VAR-GLKR-RTL-SHR-5 PS-013	12/19/2023	Draw	19.9	1.0
Pb-0161-014	FFX-JV-GLKR-HS PS-014	12/19/2023	Draw	ND	1.0
Pb-0161-015	FFX-JV-GLKR-RTL-SHR-1 PS-015	12/19/2023	Draw	24.5	1.0
Pb-0161-016	FFX-JV-GLKR-RTL-SHR-2 PS-016	12/19/2023	Draw	22.2	1.0
Pb-0161-017	FFX-JV-GLKR-RTL-SHR-3 PS-017	12/19/2023	Draw	14.2	1.0
Pb-0161-018	FFX-JV-GLKR-RTL-SHR-4 PS-018	12/19/2023	Draw	3.25	1.0
Pb-0161-019	FFX-JV-GLKR-RTL-SHR-5 PS-019	12/19/2023	Draw	5.21	1.0
Pb-0161-020	FFX-GYM-PUB-RRFGR PS-020	12/19/2023	Draw	ND	1.0
Pb-0161-021	FFX-GYM-PUB-RRFGL PS-021	not working			
Pb-0161-022	FFX-GYM-LOB-DF PS-022	12/19/2023	Draw	ND	1.0
Pb-0161-023	FFX-GYM-LOB-DW PS-023	12/19/2023	Draw	ND	1.0
Pb-0161-024	FFX-GYM-PUB-RRFBR PS-024	12/19/2023	Draw	2.44	1.0
Pb-0161-025	FFX-GYM-PUB-RRFBL PS-025	12/19/2023	Draw	2.26	1.0
Pb-0161-026	FFX-JV-BLKR-HS PS-026	12/19/2023	Draw	3.40	1.0
Pb-0161-027	FFX-JV-BLKR-RTL-SHR-1 PS-027	12/19/2023	Draw	3.64	1.0
Pb-0161-028	FFX-JV-BLKR-RTL-SHR-2 PS-028	12/19/2023	Draw	2.08	1.0
Pb-0161-029	FFX-JV-BLKR-RTL-SHR-3 PS-029	12/19/2023	Draw	18.9	1.0
Pb-0161-030	FFX-JV-BLKR-RTL-SHR-4 PS-030	12/19/2023	Draw	7.95	1.0
Pb-0161-031	FFX-JV-BLKR-RTL-SHR-5 PS-031	12/19/2023	Draw	4.77	1.0
Pb-0161-032	FFX-VAR-BLKR-HS PS-032	12/19/2023	Draw	ND	1.0
Pb-0161-033	FFX-VAR-BLKR-RTL-SHR-1 PS-033	12/19/2023	Draw	30.1	1.0
Pb-0161-034	FFX-VAR-BLKR-RTL-SHR-2 PS-034	12/19/2023	Draw	82.8	1.0
Pb-0161-035	FFX-VAR-BLKR-RTL-SHR-3 PS-035	12/19/2023	Draw	1.12	1.0
Pb-0161-036	FFX-VAR-BLKR-RTL-SHR-4 PS-036	12/19/2023	Draw	1.96	1.0

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.



Analysis Report

Total Lead by ICP-MS

Chain of Custody: Pb-0161
Facility: Fairfax R-III

Sample Matrix: Water
Method of Analysis: EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0161-037	FFX-VAR-BLKR-RTL-SHR-5 PS-037	12/19/2023	Draw	4.46	1.0
Pb-0161-038	FFX-301-HALL-DF PS-038	12/19/2023	Draw	ND	1.0
Pb-0161-039	FFX-301-HALL-DW PS-039	12/19/2023	Draw	ND	1.0
Pb-0161-040	FFX-305-SCI-HS1 PS-040	12/19/2023	Draw	3.57	1.0
Pb-0161-041	FFX-305-SCI-HS2 PS-041	12/19/2023	Draw	17.4	1.0
Pb-0161-042	FFX-305-SCI-HS3 PS-042	12/19/2023	Draw	17.7	1.0
Pb-0161-043	FFX-305-SCI-HS4 PS-043	12/19/2023	Draw	25.6	1.0
Pb-0161-044	FFX-305-SCI-HS5 PS-044	12/19/2023	Draw	33.1	1.0
Pb-0161-045	FFX-305-SCI-HS6 PS-045	12/19/2023	Draw	19.8	1.0
Pb-0161-046	FFX-2ND-FLR-RRFBR PS-046	12/19/2023	Draw	ND	1.0
Pb-0161-047	FFX-2ND-FLR-RRFBL PS-047	12/19/2023	Draw	ND	1.0
Pb-0161-048	FFX-2ND-FLR-DF PS-048	12/19/2023	Draw	ND	1.0
Pb-0161-049	FFX-2ND-FLR-DW PS-049	12/19/2023	Draw	ND	1.0
Pb-0161-050	FFX-2ND-FLR-RRFGR PS-050	12/19/2023	Draw	ND	1.0
Pb-0161-051	FFX-2ND-FLR-RRFGL PS-051	12/19/2023	Draw	ND	1.0
Pb-0161-052	FFX-1ST-GRD-8-HS PS-052	12/19/2023	Draw	ND	1.0
Pb-0161-053	FFX-1ST-GRD-8-HS-MTP PS-053	12/19/2023	Draw	ND	1.0
Pb-0161-054	FFX-NURSE-RRF PS-054	12/19/2023	Draw	ND	1.0
Pb-0161-055	FFX-NURSE-HS PS-055	12/19/2023	Draw	ND	1.0
Pb-0161-056	FFX-KIND-5-HS PS-056	12/19/2023	Draw	ND	1.0
Pb-0161-057	FFX-KIND-HALL-RRFGR PS-057	not working			
Pb-0161-058	FFX-KIND-HALL-RRFGM PS-058	12/19/2023	Draw	ND	1.0
Pb-0161-059	FFX-KIND-HALL-RRFGL PS-059	12/19/2023	Draw	ND	1.0
Pb-0161-060	FFX-KIND-HALL-DF PS-060	12/19/2023	Draw	ND	1.0
Pb-0161-061	FFX-KIND-HALL-DW PS-061	No Sample			
Pb-0161-062	FFX-KIND-HALL-RRFBR PS-062	12/19/2023	Draw	ND	1.0
Pb-0161-063	FFX-KIND-HALL-RRFBM PS-063	12/19/2023	Draw	ND	1.0
Pb-0161-064	FFX-KIND-HALL-RRFBL PS-064	12/19/2023	Draw	ND	1.0
Pb-0161-065	FFX-ART-12-HS PS-065	12/19/2023	Draw	ND	1.0
Pb-0161-066	FFX-KITCH-SC PS-066	12/19/2023	Draw	ND	1.0
Pb-0161-067	FFX-KITCH-DSH PS-067	12/19/2023	Draw	ND	1.0
Pb-0161-068	FFX-KITCH-RRF PS-068	12/19/2023	Draw	ND	1.0
Pb-0161-069	FFX-KITCH-FP PS-069	12/19/2023	Draw	ND	1.0
Pb-0161-070	FFX-LIB-HALL-RRFBR PS-070	12/19/2023	Draw	ND	1.0
Pb-0161-071	FFX-LIB-HALL-RRFBL PS-071	12/19/2023	Draw	ND	1.0
Pb-0161-072	FFX-LIB-HALL-RRFGR PS-072	12/19/2023	Draw	ND	1.0

This report has been produced for the exclusive and confidential use of our clients. Reference to the analyses, the results, or the company is prohibited without obtaining prior written consent.



Analysis Report

Total Lead by ICP-MS

Chain of Custody: Pb-0161

Facility: Fairfax R-III

Sample Matrix: Water

Method of Analysis: EPA 200.8

Laboratory Number	Customer Sample Number	Date Collected	Sample Type	Result ug/L (ppb)	Reporting Limit
Pb-0161-073	FFX-LIB-HALL-RRFGL PS-073	12/19/2023	Draw	ND	1.0
Pb-0161-074	FFX-FACS-LTR-FP1 PS-074	12/19/2023	Draw	2.85	1.0
Pb-0161-075	FFX-FACS-LTR-FP2 PS-075	12/19/2023	Draw	14.5	1.0
Pb-0161-076	FFX-FACS-LTR-FP3 PS-076	12/19/2023	Draw	2.71	1.0
Pb-0161-077	FFX-FACS-LTR-FP4 PS-077	12/19/2023	Draw	1.65	1.0
Pb-0161-078	FFX-FACS-RRF PS-078	12/19/2023	Draw	ND	1.0
Pb-0161-079	FFX-FACS-DF PS-079	12/19/2023	Draw	ND	1.0
Pb-0161-080	FFX-IS-SHOP-RRF PS-080	12/19/2023	Draw	21.2	1.0